

Questions contact – Rafael Kerguelen (781) 388-5101 or
Rafael.kerguelenstrepo@nationalgrid.com

Petition of the Massachusetts Electric Company d/b/a NATIONAL GRID
Of NORTH ANDOVER, MASSACHUSETTS
For Electric Conduit Location:

To the City Council of Malden, Massachusetts

Respectfully represents the Massachusetts Electric Company d/b/a NATIONAL GRID of North Andover, Massachusetts, that it desires to construct a line of underground electric conduits, including the necessary sustaining and protecting fixtures, under and across the public way or ways hereinafter named.

Wherefore it prays that after due notice and hearing as provided by law, it be granted permission to excavate the public highways and to run and maintain underground electric conduits, together with such sustaining and protecting fixtures as it may find necessary for the transmission of electricity, said underground conduits to be located substantially in accordance with the plan filed herewith marked – Newland Street - Malden, Massachusetts.

The following are the streets and highways referred to:

WR# 30967378

Newland Street - National Grid to install underground facilities on Newland Street. Work in the city right of way includes installing two 4" steel risers on the existing pole #3812 and approximately 51 ft of two 4" concrete encased Sch 40 PVC conduits from eastern side existing pole #3812 in front of 46 Newland Street northern direction towards 36-54 Broadway Plaza parking lot to feed the proposed pad-mounted transformer (XRFM) for a new EV charging station. Malden, MA.

Location approximately as shown on plan attached.

RECEIVED
2026 FEB 11 PM01:59
CITY CLERK'S OFFICE
MALDEN, MASS.

Massachusetts Electric Company d/b/a
NATIONAL GRID *Nick Memmolo*
BY _____
Engineering Department

Questions contact – Rafael Kerguelen (781) 388-5101 or rafael.kerguelenstrepo@nationalgrid.com

Dated: December 10, 2025

ORDERED:

Notice having been given and public hearing held, as provided by law, that the Massachusetts Electric Company d/b/a NATIONAL GRID be and it is hereby granted permission to excavate the public highways and to run and maintain underground electric conduits, together with such sustaining and protecting fixtures as said company may deem necessary, in the public way or ways hereinafter referred to, and to make the necessary house connections along said extensions, as requested in petition with said company dated the 2nd day of October, 2025.

Said underground electric conduits shall be located substantially in accordance with the plan filed herewith marked – Newland Street - Malden, Massachusetts.

The following are the public ways or part of ways along which the underground electric conduits above referred to may be laid:

WR# 30967378

Newland Street - National Grid to install underground facilities on Newland Street. Work in the city right of way includes installing two 4" steel risers on the existing pole #3812 and approximately 51 ft of two 4" concrete encased Sch 40 PVC conduits from eastern side existing pole #3812 in front of 46 Newland Street northern direction towards 36-54 Broadway Plaza parking lot to feed the proposed pad-mounted transformer (XRFM) for a new EV charging station. Malden, MA.

I hereby certify that the foregoing order was adopted at a meeting of the

.....

....., held on the day of, 20

.....,, 20

Received and entered in the records of location orders of the City/Town of

Book Page

Attest:

.....

..... hereby certify that on20....., at o'clock,M


at, a public hearing was held on the petition of Massachusetts Electric Company d/b/a NATIONAL GRID for permission to construct the

underground electric conduits described in the order herewith recorded, and that I mailed at least seven days before said hearing a written notice of the time and place of said hearing to each of the owners of real estate (as determined by the last preceding assessment for taxation) along the ways or parts of ways upon which the Company is permitted to construct the underground electric conduits under said order. And that thereupon said order was duly adopted.

.....
.....
.....



NOT TO SCALE



UG PETITION
 WR # 30967378 – 46 Newland St, Malden
SKETCH TO ACCOMPANY PETITION:
 Proposed installation of two 4" steel risers at easter side of existing Pole # 3812, and +/- 51 ft of two 4" concrete-encased Sch 40 PVC conduits under sidewalk from Pole # 3812 located in front 46 Newland St northern direction toward 36-54 Broadway parking lot of Broadway Plaza

ABBREVIATIONS

EDGE OF PAVEMENT	EDP
JOINT OWNERSHIP	JO
OVERHEAD WIRE	OHW
PROPERTY LINE	PL
POLYVINYL CHLORIDE PIPE	PVC
SIDWALK	SW
TO BE REMOVED	TBR
UNDERGROUND ELECTRIC	UGE

LEGEND

	EXISTING	PROPOSED
PROPERTY LINE	PL	
EDGE OF PAVEMENT	EDP	
UNDERGROUND ELECTRIC	UGE	UGE
OVERHEAD WIRE	OHW	OHW
POLE WITH RISER WITH POLE NO.	P.1943	P.1943 TBR



CITY OF MALDEN
 DEPARTMENT OF PUBLIC WORKS
 ENGINEERING DIVISION



DEC 2025
 REV NO. 1

PLAN NO.
 1.0